



جامعة القاهرة - كلية الهندسة  
قسم هندسة القوى الميكانيكية  
معمل التحكم الأوتوماتيكي



## MEP 440 Embaba B. Sc. Design Project- Year 2011/2012

**Investigation & Verification of 3 Automatic Control Virtual Labs: Water Tube Boiler, Steam Turbine Plant & Pumping Plant**  
by Bassam Mohammed Abdel Hakim, Sami Bakeer Ahmed Ibrahim, Shadi Mohammed Abdullah, Sherif Waheid Abdel Mongy

**Supervised by**

**Dr. Mohsen Sayed Soliman , ACC Manager**  
**Mechanical Power Engineering Department**

### Abstract:





The goals of this project are to investigate- in details- and to examine the operation and performance of 3 Automatic Control Virtual Lab Application. These Labs are: Water Tube Boiler, Steam Turbine Power Plant, and Central Pumping Plant with Tank Filling program.

### Specific Objectives of this design project:



- 1) Identifying the main concepts of industrial automatic control systems in three mechanical power applications by modern computer-based programs which simulate those practical control systems.
- 2) Investigation of the three Applications Automatic Control Virtual Labs to understand their functions, how they work and what are their input and output signals ...etc (there are more than 16 virtual labs in ACC).
- 3) Verification of accuracy and validity of the results obtained by those three virtual labs through performing engineering and scientific calibrations for those virtual labs. The calibration is done by comparing internal calculations done by those virtual labs with external engineering calculations using thermo-dynamic, conservation equations, and thermo-fluid relations to get the same output results.
- 4) Training students and engineers on Technical Report Writing and Presentation Skills for each Lab.
- 5) Enhancing the skills of Searching for information and adopting self learning capabilities related to Automatic systems and modern computer technologies.

### Contents:








- Water tube boiler  
Virtual Lab.User manual  
Controlling Technology  
Virtual Lab.Calibration
- Steam turbine Plant  
Virtual Lab.User manual  
Controlling Technology  
Virtual Lab.Calibration
- Central Pumping plant  
Virtual Lab.User manual  
Controlling Technology  
Virtual Lab.Calibration



# THW-1 Simulation of a water-tube boiler heating unit with thermal balance calculation







## Heat Balance



	Response to Load Changes	Feedwater Pressure Compensation	Shrink / Swell Protection	Mechanical Wear Compensation	Efficiency Contribution
Single Element	○	○	○	○	○
Two Element	○	○	○	○	○
Three Element	●	●	●	●	●

Performance: ○ Poor ○ Adequate ○ Good ● Best





Boiler pressure	101.9 bar
Outlet superheater pressure	100.1 bar
Inlet reheater pressure	17.3 bar
Outlet reheater pressure	15.5 bar
Feed water temperature	206 °C
Outlet economizer water temp	260 °C
Outlet superheater temperature	537 °C
Inlet reheater temperature	306 °C
Outlet reheater temperature	525 °C
Air temperature	10 °C
Exhaust temperature	160 °C
Air delivery	85024.1175 m³/h
Fuel delivery	7185.3715 kg/h
Feed water delivery	94 m³/h
Steam delivery	90 t/h

## Calibration of Virtual Lab. Program

Fuel available heat:	308,458 MJ/h
Heat to economizer:	Qe:20,160 MJ/h
Heat of vaporization:	Qc:147,330 MJ/h
Superheat:	Qs:66,330 MJ/h
Reheat:	Qrs:43,650 MJ/h
Waste heat in funnel by exhaust gas:	Qf:18,007 MJ/h
Waste heat (radiation, unburnt):	Qi:12,980 MJ/h
Efficiency:	0.900

**The Re-superheater is activated (the re-superheater outlet valve is opened)**

**Quantity of available heat in the fuel**

$$Q_d: Q_d = P_{cs} \cdot P_g = 42.070 \cdot 7185.3715 = 302289 \text{ MJ/hr} \quad Q_d = 302.289 \frac{\text{MJ}}{\text{hr}}$$

**Quantity of heat used in the economizer**

$$Q_e = P_v \cdot (h_v - h_i) = 90 \cdot 10^3 \cdot 4270 \cdot (260 - 206) = 20752 \frac{\text{MJ}}{\text{hr}} \quad Q_e = 20.752 \frac{\text{MJ}}{\text{hr}}$$

**Quantity of heat used in the generator tubes**

$$Q_g = P_v \cdot (h_v - h_e) \quad h_e = 1110.58 \frac{\text{KJ}}{\text{Kg}}$$

To get  $h_e$ ,  $Q_e = 20752 = 90 \cdot 10^3 \cdot (h_e - h_i)$ , So

$$Q_g = 90 \cdot 10^3 \cdot (2720 - 1110.58) = 144878 \frac{\text{MJ}}{\text{hr}} \quad Q_g = 144.878 \frac{\text{MJ}}{\text{hr}}$$

**Quantity of heat used in the superheater :**

$$Q_s = P_v \cdot (h_s - h_v) = 90 \cdot 10^3 \cdot (3465.2 - 2720) = 67.068 \frac{\text{MJ}}{\text{hr}} \quad Q_s = 67.068 \frac{\text{MJ}}{\text{hr}}$$

**Quantity of heat used in the re-superheater :**

$$Q_{rs} = P_v \cdot (h_{ru} - h_{re}) = 90 \cdot 10^3 \cdot (3540 - 3050) = 44.100 \frac{\text{MJ}}{\text{hr}} \quad Q_{rs} = 44.100 \frac{\text{MJ}}{\text{hr}}$$

**Quantity of heat lost in the funnel for fumes :**

$$Q_f = (P_a \cdot \beta + P_g) \cdot C_{mr} \cdot (T_f - T_a) \quad Q_f = 17.119 \frac{\text{MJ}}{\text{hr}}$$

**Quantity of heat lost for radiation and unburned:**

$$Q_i = Q_d - (Q_e + Q_g + Q_s + Q_{rs} + Q_f) \quad Q_i = 8.502 \frac{\text{MJ}}{\text{hr}}$$

## Calibration

**Comparison table between our calculations and the program calculation**

	Our Calculations	Program Calculations	Error
$Q_d$	302.289 MJ/hr	308.458 MJ/hr	2%
$Q_e$	20.752 MJ/hr	20.160 MJ/hr	-3%
$Q_g$	144.848 MJ/hr	147.330 MJ/hr	1.7%
$Q_s$	67.068 MJ/hr	66.330 MJ/hr	-1.1%
$Q_{rs}$	44.100 MJ/hr	43.650 MJ/hr	-1.03%
$Q_f$	17.119 MJ/hr	18.007 MJ/hr	4.9%
$Q_i$	8.502 MJ/hr	12.980 MJ/hr	34.5%

$$\text{Efficiency} = \frac{Q_e + Q_g + Q_s + Q_{rs}}{Q_d} \quad \text{Efficiency Calculated} = 0.916 = 91.6\%$$


$$\text{Efficiency by program} = 0.9 = 90\%$$

**Comments and Notes :**






$$\text{Error} = \frac{0.9 - 0.916}{0.9} = -1.78\%$$

**When we put error +/- 4% , We found all values are correct except  $Q_i$  error = 34.5%  
We have this large error because of C.V used in program is not correct**








# THW-2 Simulation of a Steam Turbine Plant with thermal balance calculation



Boiler pressure	43.8 bar	Electric power	0 kW
Outlet Superheater pressure	43.0 bar	Outlet Superheater temperature	430 °C
Inlet High Pressure Turbine pressure	0.0 bar	Inlet High Pressure Turbine temperature	29 °C
Outlet High Pressure Turbine pressure	0.0 bar	Outlet High Pressure Turbine temperature	29 °C
Inlet Reheater pressure	0.1 bar	Inlet Reheater temperature	73 °C
Outlet Reheater pressure	0.1 bar	Outlet Reheater temperature	73 °C
Inlet Intermediate Pressure Turbine pressure	0.0 bar	Inlet Intermediate Pressure Turbine temperature	29 °C
Inlet Condenser pressure	-0.19 bar	Inlet Condenser temperature	27 °C
Inlet I Stage steam pressure	0.01 bar	Inlet I Stage steam temperature	27 °C
Inlet II Stage steam pressure	0.0 bar	Inlet II Stage steam temperature	27 °C
Inlet III Stage steam pressure	0.0 bar	Inlet III Stage steam temperature	27 °C
Inlet IV Stage steam pressure	0.0 bar	Inlet IV Stage steam temperature	27 °C
Steam delivery	0.00 t/h	Water vapor ratio	0.000
I Bleeding delivery	0.00 t/h	II Bleeding delivery	0.00 t/h
III Bleeding delivery	0.00 t/h	IV Bleeding delivery	0.00 t/h
Air temperature	10 °C	Exhaust temperature	151 °C
Air delivery	18,200 m³/h	Fuel delivery	1,454 Kg/h
Feed water delivery	0.00 m³/h	Condenser cooling water delivery	5149.4 m³/h
Inlet Condenser cooling water temperature	4 °C	Outlet Condenser cooling water temperature	4.0 °C
Inlet I Stage feed water temperature	27 °C	Inlet Condenser condensate temperature	27 °C
Inlet II Stage feed water temperature	27 °C	Inlet I Stage condensate temperature	27 °C
Inlet III Stage feed water temperature	27 °C	Inlet III Stage condensate temperature	27 °C
Inlet IV Stage feed water temperature	27 °C	Feed water temperature	29 °C










Boiler pressure	100.1 bar	Electric power	28,658 kW
Outlet Superheater pressure	98.3 bar	Outlet Superheater temperature	533 °C
Inlet High Pressure Turbine pressure	96.2 bar	Inlet High Pressure Turbine temperature	528 °C
Outlet High Pressure Turbine pressure	16.3 bar	Outlet High Pressure Turbine temperature	312 °C
Inlet Reheater pressure	15.8 bar	Inlet Reheater temperature	306 °C
Outlet Reheater pressure	14.0 bar	Outlet Reheater temperature	525 °C
Inlet Intermediate Pressure Turbine pressure	13.6 bar	Inlet Intermediate Pressure Turbine temperature	514 °C
Inlet Condenser pressure	-0.97 bar	Inlet Condenser temperature	24 °C
Inlet I Stage steam pressure	-0.40 bar	Inlet I Stage steam temperature	129 °C
Inlet II Stage steam pressure	3.3 bar	Inlet II Stage steam temperature	348 °C
Inlet III Stage steam pressure	16.3 bar	Inlet III Stage steam temperature	307 °C
Inlet IV Stage steam pressure	45.9 bar	Inlet IV Stage steam temperature	426 °C
Steam delivery	90.53 t/h	Water vapor ratio	0.911
I Bleeding delivery	5.81 t/h	II Bleeding delivery	7.14 t/h
III Bleeding delivery	7.28 t/h	IV Bleeding delivery	10.16 t/h
Air temperature	8 °C	Exhaust temperature	155 °C
Air delivery	75,009 m³/h	Fuel delivery	6,339 Kg/h
Feed water delivery	94.53 m³/h	Condenser cooling water delivery	5071.6 m³/h
Inlet Condenser cooling water temperature	2 °C	Outlet Condenser cooling water temperature	82 °C
Inlet I Stage feed water temperature	34 °C	Inlet Condenser condensate temperature	82 °C
Inlet II Stage feed water temperature	85 °C	Inlet I Stage condensate temperature	141 °C
Inlet III Stage feed water temperature	145 °C	Inlet III Stage condensate temperature	254 °C
Inlet IV Stage feed water temperature	204 °C	Feed water temperature	263 °C



**Including both of the re-superheater and all of four water heaters # I, II, III, and IV in the plant:**

Boiler pressure	100.2 bar	Outlet Superheater pressure	98.4 bar
Inlet High Pressure Turbine pressure	96.3 bar		
Outlet High Pressure Turbine pressure	16.4 bar		
Inlet Reheater pressure	15.8 bar		
Outlet Reheater pressure	14.0 bar		
Inlet Intermediate Pressure Turbine pressure	13.6 bar		
Inlet Condenser pressure	-0.97 bar		
Inlet I Stage steam pressure	-0.40 bar		
Inlet II Stage steam pressure	3.4 bar		
Inlet III Stage steam pressure	16.4 bar		
Inlet IV Stage steam pressure	46.0 bar		
Outlet Superheater temperature	534 °C		
Inlet High Pressure Turbine temperature	529 °C		
Outlet High Pressure Turbine temperature	312 °C		
Inlet Reheater temperature	306 °C		
Outlet Reheater temperature	525 °C		
Inlet Intermediate Pressure Turbine temperature	514 °C		
Inlet Condenser temperature	24 °C		
Inlet I Stage steam temperature	130 °C		
Inlet II Stage steam temperature	348 °C		
Inlet III Stage steam temperature	307 °C		
Inlet IV Stage steam temperature	427 °C		

## Calibration of Virtual Lab. Program

Fuel available heat:.....269,542 MJ/h  
 Shaft horsepower.....Pu:104,314 MJ/h  
 Heat lost in the funnel by exhaust gas.....Qf:15,736 MJ/h  
 Subtracted heat from the condenser.....Qa:132,519 MJ/h  
 Other loss (radiation, mechanical,...).....Qi:16,975 MJ/h  
 Efficiency.....0.387  
 Steam specific consumption.....0.221 kg/kWh  
 Fuel specific consumption.....3.16 kg/kWh

• **Available heat ( $Q_d$ )** :  $Q_d = m_f \cdot C.V = 6.409 \cdot 42 = 269.178 \text{ MJ/Kg}$

• **Power at Turbine axle ( $P_u$ )** :  $P_u = m_s \cdot (h_2 - h_7) + (m_s - m_{IV})(h_7 - h_8) + (m_s - m_{IV} - m_{III})(h_8 - h_9) + (m_s - m_{IV} - m_{III} - m_{II})(h_9 - h_{10}) + (m_s - m_{IV} - m_{III} - m_{II} - m_I)(h_{10} - h_{11})$

Knowing that :

State	Mass Rate (Kg/hr)
$m_s$	91.54
$m_I$	5.85
$m_{II}$	7.22
$m_{III}$	7.36
$m_{IV}$	10.27

So, Sub in the above equation by enthalpies and mass flow rates, get :

• **Pump Power ( $P_{pump}$ )** :  $P_{pump} = (m_s - m_{IV} - m_{III})(h_{18} - h_{17}) + (m_s)(h_{13} - h_{12})$   
 $P_{pump} = (91.54 - 10.27 - 7.36) \cdot (147 - 47) + 91.54 \cdot (1184 - 1128) = 9.229 \frac{\text{MJ}}{\text{hr}}$

So, • **Power Net ( $P_{net}$ )** :  $P_{net} = P_u - P_{pump} = 112.43 - 9.223 = 103.207 \frac{\text{MJ}}{\text{hr}}$

So, • **Lost heat at chimney for fume ( $Q_f$ )** :  
 $Q_f = [\text{air delivery } (V_{1a}) \cdot \text{air density } ((\rho_{1a})) + \text{fuel delivery } (m_{1f})] \cdot [\text{fume specific heat } (C_{p1}) \cdot \text{fume}]$   
 $Q_f = (75.842 \cdot 1.2 + 6.409) \cdot 1 \cdot (158 - 11) = 14257 \frac{\text{KJ}}{\text{hr}}$

• **Heat taken from the condenser ( $Q_a$ )** :  
 $Q_a = [\text{condenser cooling water delivery } \cdot (\text{water temperature at condenser exit} - \text{water temperature at condenser inlet}) \cdot \text{water specific heat}]$   
 $Q_a = (\rho_w \cdot V_w) \cdot C_{pw} \cdot (T_{w,o} - T_{w,in})$   
 $Q_a = (10^3 \cdot 5127.9) \cdot 4.18 \cdot (11.2 - 5) = 132.894656 \frac{\text{MJ}}{\text{hr}}$

Therefore,  $Q_a = 132.894656 \frac{\text{MJ}}{\text{hr}}$   
 • **Other losses (radiation, incombustibles, mechanicals, etc.) ( $Q_i$ )** :  
 $Q_i = Q_d - Q_f - P_{net}$   
 $Q_i = 269.78 - (132.895 + 14.257 + 103.207) = 18.783 \frac{\text{MJ}}{\text{hr}}$

• **Efficiency** :  $\eta = \frac{P_{net}}{Q_d} = \frac{103.207}{269.78} = 0.383$

• **Steam Specific Consumption ( $C_s$ )** :

$$C_s = \frac{m_s}{P_{turbine}} = \frac{91.54 \cdot 10^3}{103.207 \cdot 3600} = 3193 \frac{\text{Kg}}{\text{KW}_h}$$
















$$C_s = 3193 \frac{\text{Kg}}{\text{KW}_h}$$





• **Fuel Specific Consumption ( $C_f$ )** :

$$C_f = \frac{m_f}{P_{turbine}} = \frac{6.409 \cdot 10^3}{103.207 \cdot 3600} = 223.6 \frac{\text{Kg}}{\text{KW}_h} \quad C_f = 223.6 \frac{\text{Kg}}{\text{KW}_h}$$



# THW-10 Principles of Hydraulics & Centrifuge Pump Plant(2 programs)





## Diagnostic (C:\Program Files\PumpsHydraulic\PARALLEL.DTS)

Options Tables Help

Table 1 of 1

Pump 1	Voltage	Current	Delivery	Delivery Pressure	Suction Pressure	Revolution
	Volt	Ampere	m³/h	Bar	Bar	r.p.m.
1	140	11	7.1	3.4	-0.08	2842
2	140	11	8	3.37	-0.09	2842
3	140	12	8.9	3.34	-0.11	2842
4	140	12	9.8	3.3	-0.12	2842
5	140	13	10.8	3.25	-0.14	2842
6	140	13	11.2	3.23	-0.15	2842
7	140	13	12.1	3.18	-0.16	2842
8	140	13	13.1	3.13	-0.18	2842
9	140	14	14	3.07	-0.19	2842
10	140	14	14.9	3.01	-0.21	2842
11	140	14	15.4	2.98	-0.22	2842
12	140	15	15.8	2.95	-0.22	2842
13	140	15	16.3	2.91	-0.23	2842
14	140	15	16.7	2.88	-0.24	2842
15	140	15	17	2.86	-0.24	2842
16	140	15	17.4	2.83	-0.25	2842
17	140	16	18.1	2.77	-0.26	2842
18	140	16	18.6	2.73	-0.27	2842

Pump 2	Voltage	Current	Delivery	Delivery Pressure	Suction Pressure	Revolution
	Volt	Ampere	m³/h	Bar	Bar	r.p.m.
1	139	10	7.1	3.4	-0.08	2761
2	139	11	8	3.37	-0.09	2761
3	139	11	8.9	3.34	-0.11	2761
4	139	12	9.8	3.3	-0.12	2761
5	139	12	10.8	3.25	-0.14	2761
6	139	12	11.2	3.23	-0.15	2761
7	139	13	12.1	3.18	-0.16	2761
8	139	13	13.1	3.13	-0.18	2761
9	139	13	14	3.07	-0.19	2761
10	139	14	14.9	3.01	-0.21	2761
11	139	14	16.1	2.93	-0.23	2761
12	139	15	17	2.86	-0.24	2761
13	139	15	17.9	2.79	-0.26	2761
14	139	16	18.8	2.71	-0.27	2761
15	139	16	19.7	2.63	-0.29	2761
16	139	17	20.7	2.55	-0.31	2761
17	139	17	21.6	2.46	-0.32	2761
18	139	18	22.7	2.35	-0.34	2761

## PUMP TOTAL HEAD

The total head of a pump is the difference between the energy level at the pump discharge (point 2) and that at the pump suction (point 1), as shown in Figures 7 and 8. Applying Bernoulli's equation (Eq. 1) at each point, the pump total head  $TH$  in feet (meters) becomes

$$TH = H_d - H_s = \left( \frac{V_d^2}{2g} + \frac{p_d}{\gamma} + Z_d \right) - \left( \frac{V_s^2}{2g} + \frac{p_s}{\gamma} + Z_s \right) \quad \text{where} \quad H = \frac{V^2}{2g} + \frac{p}{\gamma} + Z$$

$H$  = total head of system, (+) or (-) ft (m) gage or (+) ft (m) abs

$P$  = total pressure of system, (+) or (-) lb/ft² (N/m²) gage or (+) lb/ft² (N/m²) abs

$V$  = velocity, ft/s (m/s)



$p$  = pressure, (+) or (-) lb/ft² (N/m²) gage or (+) lb/ft² (N/m²) abs

$Z$  = elevation above (+) or below (-) datum plane, ft (m)

$\gamma$  = specific weight (force) of liquid, lb/ft³ (N/m³)

$g$  = acceleration of gravity, 32.17 ft/s² (9.807 m/s²)

pump differential pressure  $TH = \frac{P_{\Delta}}{\gamma}$



**FLOW/SPEED VALUES**

Output flow m³/s : 0.34 same values

Output speed m/s : 10.60

Input flow m³/s : 0.34

**WORKING DATA**

Tank volume m³ : 200

Tank height m : 12

Liquid density kg/m³ : 1025

Section of outflow m² : 0.032

**VENTURI METER VALUES**

Liquid density kg/m³ : 13.590

Throttling ratio : 1.2

Difference in height m : 0.206

**THE FILL TIME**

Hours, minutes, seconds : 04.55.33

**Level**

Piezometric height : 5.73 [m]

Hydrostatic pressure : 57568 [Pa]

**fixed surface level**

**fixed height**